

## **SALIENT FEATURES**

- IGBT based double conversion on-line Topology
- DSP/Microprocessor Controlled
- Wide Input Range
- LCD Display
- Charger for extended backup time
- Scalable Battery option
- Generator Compatible



## **CERTIFICATION**

RoHS

• OHSAS 18001

• ISO 9001

• ISO 14001

Address: 66 Salkia School Road, 'AAVAS', B Block, Howrah - 711 106 Phone: 8420007562

E-Mail: service@epochelectronica.com



## TECHNICAL SPECIFICATIONS FOR EPOCH 10KVA (3:1)ON-LINE UPS SYSTEM

| MODEL                 | 3AM 10000   |
|-----------------------|---|
| Capacity              | 10KVA   |
| INPUT                 |   |
| Voltage Range         | 345 to 465V (It may be changed as per customer)             |
| Frequency             | 45 to 55Hz  |
| Power Factor          | 0.99 to unity   |
| OUTPUT                |   |
| Voltage               | 230VAC  |
| Regulation            | ±1%   |
| Frequency             | 50Hz ± 0.05% in free running mode                           |
| Waveform              | Pure sine wave  |
| Harmonic Distortion   | < 3% at full load (non linear load)                         |
|                       | < 2% (linear load)  |
| Crest Factor          | 03:01   |
| Overload Capacity     | 110% - for 10 min   |
|                       | 150% - for 5 cycles   |
| Output Power Factor   | 0.8   |
| BATTERY               |   |
| DC Bus Voltage        | 240 V   |
| Charger Type          | Built-in solid state float-cum-boost charger with           |
|                       | automatic boost/trickle                                     |
| Transfer Time         | 0 ms  |
| Battrey Type          | VRLA-SMF  |
| Charging Current      | 10% of Battrey AH   |
| INDICATOR             |   |
| Multi Function        | Battery Level, Load Level, AC Mode, Battery Mode            |
| LED Display/LCD       | By Pass Mode,fault indicator                                |
| Display               |   |
| METERING              |   |
| LCD Display           | Input Voltage,Input Frequency, Output Voltage, Output       |
|                       | Frequency, Output Current, Percentage Load. DC Voltage      |
| AUDIBLE ALARM         | Trequency, output current, Fercentage Load. De Voltage      |
| AC Failure            | Every 4 seconds   |
| Battery Low           | Every 4 seconds  Every seconds when approaches to low level |
| UPS Fault             | Continuous alarm  |
| PROTECTION            | Continuous didiffi  |
| Electronic Protection | Output overload, short circuit, Over temp, Battery low,     |
|                       | Over charge,Input Voltage high/low                          |
| FEEECIENCY            | Over charge, input voitage mgm/10w                          |
| Overall               | 970/  |
| Overall               | 87%   |
| Inverter              | > 90%   |
| AMBIENT CONDITION     | 0. / 0. do grad a santi grad d                              |
| Temperature           | 0-40 degree centigrade                                      |
| Humidity              | 0-95% at non condensing                                     |
| Audible Noise         | < 60 db at 1 metre  |

Address : 66 Salkia School Road, 'AAVAS', B Block, Howrah - 711 106

Phone: 8420007562

E-Mail:service@epochelectronica.com